



Certificate of Compliance

Certificate: 70106262 **Master Contract:** 263247 (263247)

Project: 70131390 **Date Issued:** 2017-05-05

Issued to: JC-TL Ball Valve Corp
20675 Boul. Industriel
Ste. Anne-de-Bellevue, Quebec H9X 4B2
CANADA
Attention: Sanjay Sharma

The products listed below are eligible to bear the CSA Mark shown with adjacent indicators 'C' and 'US' for Canada and US or with adjacent indicator 'US' for US only or without either indicator for Canada only.



Issued by: Vajira Sarathchandra
Vajira Sarathchandra

PRODUCTS

CLASS - C337190 - VALVES (GAS)-Lever Operated Non-Lubricated-Shutoff-Certified to U.S. Standards

CLASS - C337110 - VALVES (GAS)-Lever Operated Non-Lubricated Shutoff

Manual Operated Ball Valve FIG. 515 Series – ½”, ¾”, 1”, 1½”, 2”, 3”, 4”, 6”, 8”

– Carbon Steel & Stainless Steel Options

ANSI CLASS 150 rated

Lever Operated Shut-Off Valve,

Minimum Operating Temperature: -30°C

Maximum Operating Temperature: 180°C

APPLICABLE REQUIREMENTS

- | | | |
|------------------|---|-----------------------------------------------------------------------------------------------------------|
| CSA 3.16-2015 | - | Lever Operated Non-Lubricated Gas Shut-Off Valves |
| ASME B16.33-2012 | - | Manually Operated Metallic Gas Valves for Use in Piping Systems Up to 175 PSI (Sizes NPS ½ through NPS 2) |
| ASME B16.38-2012 | - | Large Metallic Gas Valves for Gas Distribution (NPS 2½ to NPS 12, 125 PSIG) |



Supplement to Certificate of Compliance

Certificate: 70106262

Master Contract: 263247 (263247)

*The products listed, including the latest revision described below,
are eligible to be marked in accordance with the referenced Certificate.*

Product Certification History

Project	Date	Description
70131390	2017-05-05	Approval of 515 Series Ball Valves to ASME B16.33/38 (2012)
70106262	2017-03-03	Original Certification (WMTC) of Fig. 515 Carbon Steel & Stainless Steel Series (Sizes 1/2" to 8") to CSA 3.16-2015.